



Remove the two #8-32 flat head screws to remove the crossbar.




CAUTION: Turn the power to electrical box off!

Mount the crossbar to the electrical box with the provided two #8-32 screws.



- 13 Hook the transformer safety wire onto the crossbar bracket.
- Onnect the crossbar green wire to the ground in accordance with local electrical codes.
- Connect the transformer white wire to the neutral power line wire with a wire nut.
- Onnect the transformer black wire to the hot power line wire with a wire nut.




- Slide the transformer onto the crossbar.
- Align the transformer holes with the crossbar holes; replace and tighten the two #8-32 flat head screws.

PWMSMT300




Connect the Monorail to Transformer



NOTE: The standoffs should be installed to support the Monorail while connecting Monorail to the surface mount transformer. Refer to the instruction provided with the standoffs.

- Remove the power feed cap from the power feed housing.
- Completely back out the screw on the power feed cap.





- Place a Monorail section into the standoffs and power feed housings.
- Screw the power feed cap completely to the power feed housing. Make sure that the power feed cap is not cross threaded.